	2005 (Year of Plenty; No water Hauling)								2006 (Year of Shortage; 675,000 gallons hauled)								2007 (Year of Drought; 3,683,000 gallons hauled)							
	Pine				Strawberry				Pine				Strawberry				Pine				Strawberry			
Month	# Customers	Gallons Used (thousands)	Usage per Customer	Average GPM	# Customers	Gallons Used (thousands)	Usage per Customer	Average GPM	# Customers	Gallons Used (thousands)	Usage per Customer	Average GPM	# Customers	Gallons Used (thousands)	Usage per Customer	Average GPM	# Customers	Gallons Used (thousands)	Usage per Customer	Average GPM	# Customers	Gallons Used (thousands)	Usage per Customer	Average GPM
May	1996	3684	1846	82.5	1036	2105	2032	47.2	2012	4929	2450	110.4	1056	2847	2696	63.8	2010	3765	1873	84.3	1067	2961	2775	66.3
June	1986	4967	2501	115.0	1033	3029	2932	70.1	2027	6104	3011	141.3	1059	3984	3762	92.2	2012	5117	2543	118.4	1072	4074	3800	94.3
July	1996	5889	2950	131.9	1043	3786	3630	84.8	2018	5496	2723	123.1	1058	4507	4260	101.0	2013	4926	2447	110.3	1072	3852	3593	86.3
August	1992	5429	2725	121.6	1031	4417	4284	98.9	2017	4159	2062	93.2	1058	3677	3475	82.4	2014	3696	1835	82.8	1080	2994	2772	67.1
September	1997	4434	2220	102.6	1032	2659	2577	59.6	2016	4391	2178	98.4	1061	2574	2426	57.7	2013	4281	2127	95.9	1076	2745	2551	61.5
Total	1993.4	24403	2448	110.8	1035	15996	3091	72.6	2018	25079	2486	113.8	1058.4	17589	3324	79.8	2012.4	21785	2165	98.9	1073.4	16626	3098	75.5
System Totals																								
May	3032	5789	1909	129.7					3068	7776	2535	174.2					3077	6726	2186	150.7				
June	3019	7996	2649	185.1					3086	10088	3269	233.5					3084	9191	2980	212.8				
July	3039	9675	3184	216.7					3076	10003	3252	224.1					3085	8778	2845	196.6				
August	3023	9846	3257	220.6					3075	7836	2548	175.5					3094	6690	2162	149.9				
September	3029	7093	2342	164.2					3077	6965	2264	161.2					3089	7026	2275	162.6				
Total	3028.4	40399	2668	183.4					3076.4	42668	2774	193.7					3085.8	38411	2490	174.3				
Peak Month Usage (gpm)	233.5																							
Water Loss Estimate (%)	15.0%																							
Peak Month Error margin (%)	10.0%																							
Peak Month Supply (gpm)	291.9																							
Growth in Pine Usage to match Strawberry (gpm)	40.5																							
Total to cover today (gpm)	332.4																							
Pine Capacity:																								
BT-1	12.5	405250	9.4																					
BT-2	13	435980	10.1																					
CT	8.5	159180	3.7																					
SH-1	12.5	141640	3.3																					
SH-2	7	64110	1.5																					
SH-3	13.5	149550	3.5																					
P-1	18	355260	8.2																					
PW-2	16	315220	7.3																					
PW-3	26	863400	20.0																					
CS	5	129390	3.0																					
STWID1 (WSA)	30	1015600	23.5																					
STWID2 (WSA)	5.5	67880	1.6																					
B (WSA)	22	407000	9.4																					
W (WSA)	21.5	444800	10.3																					
BT-4 (WSA)	14.5	480390	11.1																					
STWID Master Meter		-107800	-2.5																					
Total	225.5	5326850	123.3																					
Strawberry Capacity:																								
RW	15	105710	2.4																					
SV-3	10	39270	0.9																					
SV-1	15	228000	5.3																					
SR-5	15	169700	3.9																					
TF	24	868770	20.1																					
K-2	7.5	50400	1.2																					
SCF	10	3060	0.1																					
M (WSA)	25	858680	19.9																					
J1 (WSA)	28	607600	14.1																					
J2 (WSA)	11	243500	5.6																					
W (WSA)	15.5	405700	9.4																					
H1 (WSA)	20	3100	0.1																					

H2 (WSA)	10	0	0.0																							
Total	206	3583490	83.0																							
Total, Both	431.5	8910340	206.3																							
PSWID Owned Capacity	228.5	4483890	103.8																							
	53.0%	50.3%	50.3%																							
WSA Capacity	203	4426450	102.46412																							
	47.0%	49.7%	49.7%																							
SH3 Deep Well	27																									
Total, Both	458.5																									
PSWID Owned Capacity	255.5																									
	55.7%																									
WSA Capacity	203																									
	44.3%																									